

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1574:146

Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ 07004-1561  
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

**DESIGN:** Models 4220-135, 4220-197, 4222-135 and 4222-197. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, temperature/electrical ratings and UL label.

**APPROVAL:** Listed as system heat detectors for use with separately listed compatible control units.

**NOTE:** Formerly 7270-0085:132

**XLF:** 7270-0073:039

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager